



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

June 24, 2021

David McKeighan
Hudson Falls Central Schools
PO Box 710
Hudson Falls, NY 12839
TEL: 518 786-3244

Work Order No: 210614047
PO#: 2022112

RE:

Intermediate School

Dear David McKeighan:

Adirondack Environmental Services, Inc received 50 samples on 6/14/2021 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

ELAP#: 10709

Tara Daniels
Laboratory Director

Adirondack Environmental Services, Inc

CASE NARRATIVE

Hudson Falls Central Schools

Date: 24-Jun-21

Intermediate School

Lab WorkOrder: 210614047

Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 24-Jun-21

CLIENT: Hudson Falls Central Schools**LabWork Order:** 210614047**Project:** Intermediate School**PO#:** 2022112**Lab SampleID:** 210614047-001**Collection Date:** 6/12/2021**Client Sample ID:** IN-KT-1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 12:55:35 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210614047-002**Collection Date:** 6/12/2021**Client Sample ID:** IN-KT-2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 1:06:48 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-003**Collection Date:** 6/12/2021**Client Sample ID:** IN-KTB-1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.1	1.0		µg/L	1	6/23/2021 1:18:00 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-004**Collection Date:** 6/12/2021**Client Sample ID:** IN-NUR-1**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 1:21:45 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-005**Collection Date:** 6/12/2021**Client Sample ID:** IN-NUR-2**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 1:25:30 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 24-Jun-21

CLIENT: Hudson Falls Central Schools**LabWork Order:** 210614047**Project:****PO#:** 2022112

Intermediate School

Lab SampleID: 210614047-006**Collection Date:** 6/12/2021**Client Sample ID:** IN-01-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	6.3	1.0		µg/L	1	6/23/2021 1:29:16 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-007**Collection Date:** 6/12/2021**Client Sample ID:** IN-02-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.6	1.0		µg/L	1	6/23/2021 1:33:02 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-008**Collection Date:** 6/12/2021**Client Sample ID:** IN-MFB**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 1:36:48 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-009**Collection Date:** 6/12/2021**Client Sample ID:** IN-GFB**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 1:40:35 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-010**Collection Date:** 6/12/2021**Client Sample ID:** IN-03-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 1:44:17 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 24-Jun-21

CLIENT: Hudson Falls Central Schools**LabWork Order:** 210614047**Project:****PO#:** 2022112

Intermediate School

Lab SampleID: 210614047-011**Collection Date:** 6/12/2021**Client Sample ID:** IN-03-B**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 1:48:00 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-012**Collection Date:** 6/12/2021**Client Sample ID:** IN-NUR/C**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.9	1.0		µg/L	1	6/23/2021 2:06:37 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-013**Collection Date:** 6/12/2021**Client Sample ID:** IN-05-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 2:10:21 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-014**Collection Date:** 6/12/2021**Client Sample ID:** IN-05-B**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.1	1.0		µg/L	1	6/23/2021 2:14:05 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-015**Collection Date:** 6/12/2021**Client Sample ID:** IN-06-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 2:17:49 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 24-Jun-21

CLIENT: Hudson Falls Central Schools**LabWork Order:** 210614047**Project:****PO#:** 2022112

Intermediate School

Lab SampleID: 210614047-016**Collection Date:** 6/12/2021**Client Sample ID:** IN-06-B**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	2.0	1.0		µg/L	1	6/23/2021 2:21:34 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-017**Collection Date:** 6/12/2021**Client Sample ID:** IN-07-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 2:25:19 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-018**Collection Date:** 6/12/2021**Client Sample ID:** IN-07-B**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 2:29:04 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-019**Collection Date:** 6/12/2021**Client Sample ID:** IN-08**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.2	1.0		µg/L	1	6/23/2021 2:32:49 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-020**Collection Date:** 6/12/2021**Client Sample ID:** IN-09**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 2:36:32 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 24-Jun-21

CLIENT: Hudson Falls Central Schools**LabWork Order:** 210614047**Project:** Intermediate School**PO#:** 2022112**Lab SampleID:** 210614047-021**Collection Date:** 6/12/2021**Client Sample ID:** IN-10-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.4	1.0		µg/L	1	6/23/2021 2:55:08 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-022**Collection Date:** 6/12/2021**Client Sample ID:** IN-10-B**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 3:06:20 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-023**Collection Date:** 6/12/2021**Client Sample ID:** IN-11**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.4	1.0		µg/L	1	6/23/2021 3:10:04 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-024**Collection Date:** 6/12/2021**Client Sample ID:** IN-12**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 3:13:48 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-025**Collection Date:** 6/12/2021**Client Sample ID:** IN-13**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	2.4	1.0		µg/L	1	6/23/2021 3:17:33 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 24-Jun-21

CLIENT: Hudson Falls Central Schools**LabWork Order:** 210614047**Project:****PO#:** 2022112

Intermediate School

Lab SampleID: 210614047-026**Collection Date:** 6/12/2021**Client Sample ID:** IN-14**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 3:21:19 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-027**Collection Date:** 6/12/2021**Client Sample ID:** IN-DF-1-BF**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 3:32:32 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-028**Collection Date:** 6/12/2021**Client Sample ID:** IN-15-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 3:36:14 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-029**Collection Date:** 6/12/2021**Client Sample ID:** IN-16-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 3:39:57 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-030**Collection Date:** 6/12/2021**Client Sample ID:** IN-17-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 3:43:40 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 24-Jun-21

CLIENT: Hudson Falls Central Schools**LabWork Order:** 210614047**Project:****PO#:** 2022112

Intermediate School

Lab SampleID: 210614047-031**Collection Date:** 6/12/2021**Client Sample ID:** IN-18-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 3:47:24 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-032**Collection Date:** 6/12/2021**Client Sample ID:** IN-19**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	2.8	1.0		µg/L	1	6/23/2021 3:58:35 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-033**Collection Date:** 6/12/2021**Client Sample ID:** IN-20**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 4:02:19 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-034**Collection Date:** 6/12/2021**Client Sample ID:** IN-21**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 4:06:03 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-035**Collection Date:** 6/12/2021**Client Sample ID:** IN-22**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 4:17:16 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 24-Jun-21

CLIENT: Hudson Falls Central Schools**LabWork Order:** 210614047**Project:****PO#:** 2022112

Intermediate School

Lab SampleID: 210614047-036**Collection Date:** 6/12/2021**Client Sample ID:** IN-23**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 4:21:01 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-037**Collection Date:** 6/12/2021**Client Sample ID:** IN-24**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 4:24:46 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-038**Collection Date:** 6/12/2021**Client Sample ID:** IN-25**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 4:28:30 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-039**Collection Date:** 6/12/2021**Client Sample ID:** IN-26**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 4:32:13 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-040**Collection Date:** 6/12/2021**Client Sample ID:** IN-27**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 4:35:56 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 24-Jun-21

CLIENT: Hudson Falls Central Schools**LabWork Order:** 210614047**Project:****PO#:** 2022112

Intermediate School

Lab SampleID: 210614047-041**Collection Date:** 6/12/2021**Client Sample ID:** IN-28A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 4:47:07 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-042**Collection Date:** 6/12/2021**Client Sample ID:** IN-28B**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.1	1.0		µg/L	1	6/23/2021 5:05:48 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-043**Collection Date:** 6/12/2021**Client Sample ID:** IN-28C**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 5:09:33 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-044**Collection Date:** 6/12/2021**Client Sample ID:** IN-B-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 5:13:18 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-045**Collection Date:** 6/12/2021**Client Sample ID:** IN-B-B**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	2.5	1.0		µg/L	1	6/23/2021 5:17:03 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 24-Jun-21

CLIENT: Hudson Falls Central Schools**LabWork Order:** 210614047**Project:****PO#:** 2022112

Intermediate School

Lab SampleID: 210614047-046**Collection Date:** 6/12/2021**Client Sample ID:** IN-04-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/23/2021 5:20:47 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614047-047**Collection Date:** 6/12/2021**Client Sample ID:** IN-04-B**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.3	1.0		µg/L	1	6/23/2021 5:24:31 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-048**Collection Date:** 6/12/2021**Client Sample ID:** IN-HW-A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.7	1.0		µg/L	1	6/23/2021 5:28:15 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-049**Collection Date:** 6/12/2021**Client Sample ID:** IN-HW-B**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.7	1.0		µg/L	1	6/23/2021 5:31:59 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614047-050**Collection Date:** 6/12/2021**Client Sample ID:** IN-HW-C**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.4	1.0		µg/L	1	6/23/2021 5:35:43 PM
------	-----	-----	--	------	---	----------------------



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210614047

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Hudson Falls CSD	Address: 139 Maple St. Hudson Falls NY 12839
Send Report to: David McKeighan dmckeighan@hfcscd.org	Project Name (Location): Intermediate School
Client Phone #: 518-681-4572	Client PO #: 2022112
Client Email: dmckeighan@hfcscd.org	Samplers Name: David McKeighan
	Samplers Signature: <i>David McKeighan</i>

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
001	IN-KT-1	6/12/21	8:30	A					
002	IN-KT-2			P					
003	IN-KTB-1			A					
004	IN-NUR-1			P					
005	IN-NUR-2			A					
006	IN-01-A			P					
007	IN-02-A			A					
008	IN-MFB			P					
009	IN-GFB			A					
010	IN-03-A			P					
011	IN-03-B			A					
012	IN-NUR/C			P					
013	IN-05-A			A					
014	IN-05-B			P					
015	IN-06-A			A					

Shipment Arrived Via:
FedEx UPS Client AES Other: _____

Special Instructions/Remarks:

Turnaround Time Requested:

1 Day 2 Day 3 Day 5 Day Standard

NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time
	<i>[Signature]</i>	6/14/21	2:42pm

Sample Temperature <u>Ambient</u> ~ Chilled ~ Chilling Begun Notes: 22°C		Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____		Received Within Holding Times: <u>Y</u> / N Notes:
Custody Seal Intact: Y / N				
Bottles AES: <u>Y</u> / N				



210614047



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210614047

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Hudson Falls CSD		Address: 139 Maple St. Hudson Falls NY 12839					
Send Report to: David McKeighan dmckeighan@hfcscd.org		Project Name (Location): Intermediate School			Samplers Name: David McKeighan		
Client Phone #: 518-681-4572		Client PO #: 2022112			Samplers Signature: <i>David McKeighan</i>		
Client Email: dmckeighan@hfcscd.org							

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
016	IN-06-B	6/12/21	A						
017	IN-07-A		P						
018	IN-07-B		P						
019	IN-08		P						
020	IN-09		P						
021	IN-10-A		P						
022	IN-10-B		P						
023	IN-11		9:45	P					
024	IN-12			P					
025	IN-13			P					
026	IN-14			P					
027	IN-DF-1-BF			P					
028	IN-15-A			P					
029	IN-16-A			P					
030	IN-17-A			P					

Shipment Arrived Via: FedEx UPS <u>Client</u> AES Other:		Special Instructions/Remarks:	
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.			

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time
	<i>[Signature]</i>	6/14/21	2:43pm

Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes: 22°C	Properly Preserved: (Y) / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: (Y) / N Notes:
Custody Seal Intact: Y / N		
Bottles AES: (Y) / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210614047

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Hudson Falls CSD	Address: 139 Maple St. Hudson Falls NY 12839	
Send Report to: David McKeighan dmckeighan@hfcscd.org	Project Name (Location): Intermediate School	Samplers Name: David McKeighan
Client Phone #: 518-681-4572	Client PO #: 2022112	Samplers Signature: <i>David McKeighan</i>
Client Email: dmckeighan@hfcscd.org		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
031	IN-18-A	6/12/21	A						
032	IN-19		P						
033	IN-20		A						
034	IN-21		P						
035	IN-22		A						
036	IN-23		P						
037	IN-24		A						
038	IN-25		P						
039	IN-26		A						
040	IN-27		P						
041	IN-28A		A						
042	IN-28B		P						
043	IN-28C		A						
044	IN-B-A		P						
045	IN-B-B		A						

Shipment Arrived Via: FedEx UPS <u>Client</u> AES Other: _____	Special Instructions/Remarks:
---	-------------------------------

Turnaround Time Requested:
1 Day 2 Day 3 Day 5 Day Standard
NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time

Sample Temperature <u>Ambient</u> ~ Chilled ~ Chilling Begun Notes: 22°C	Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
Custody Seal Intact: Y / N		
Bottles AES: Y / N		



CHAIN OF CUSTODY RECORD

AES Work Order#:

210614047

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

[illegible]

4 of 4



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.