



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

June 25, 2021

David McKeighan
Hudson Falls Central Schools
PO Box 710
Hudson Falls, NY 12839
TEL: 518 786-3244

Work Order No: 210614052
PO#: 2022112

RE:

Primary School

Dear David McKeighan:

Adirondack Environmental Services, Inc received 58 samples on 6/14/2021 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Christopher Hess
QA Manager

ELAP#: 10709

Adirondack Environmental Services, Inc

CASE NARRATIVE

Hudson Falls Central Schools

Date: 25-Jun-21

Primary School

Lab WorkOrder: 210614052

Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 25-Jun-21

CLIENT: Hudson Falls Central Schools

LabWork Order: 210614052

Project:

Primary School

PO#: 2022112

Lab SampleID: 210614052-001

Collection Date: 6/12/2021

Client Sample ID: PS-KT-1

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.2	1.0		µg/L	1	6/24/2021 4:59:01 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614052-002

Collection Date: 6/12/2021

Client Sample ID: PS-KT-2

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	2.3	1.0		µg/L	1	6/24/2021 5:10:12 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614052-003

Collection Date: 6/12/2021

Client Sample ID: PS-KT-3

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 5:13:56 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-004

Collection Date: 6/12/2021

Client Sample ID: PS-KTB

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.1	1.0		µg/L	1	6/24/2021 5:17:41 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614052-005

Collection Date: 6/12/2021

Client Sample ID: PS-OFF

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 5:28:53 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 25-Jun-21

CLIENT: Hudson Falls Central Schools

LabWork Order: 210614052

Project:

Primary School

PO#: 2022112

Lab SampleID: 210614052-006

Collection Date: 6/12/2021

Client Sample ID: PS-NURSE-1

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 5:32:35 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-007

Collection Date: 6/12/2021

Client Sample ID: PS-NUR-2

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 5:36:18 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-008

Collection Date: 6/12/2021

Client Sample ID: PS-01-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 5:40:01 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-009

Collection Date: 6/12/2021

Client Sample ID: PS-02-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 5:43:44 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-010

Collection Date: 6/12/2021

Client Sample ID: PS-03-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	13.9	1.0		µg/L	1	6/24/2021 5:47:27 PM
------	------	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 25-Jun-21

CLIENT: Hudson Falls Central Schools

LabWork Order: 210614052

Project:

Primary School

PO#: 2022112

Lab SampleID: 210614052-011

Collection Date: 6/12/2021

Client Sample ID: PS-03-B

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.8	1.0		µg/L	1	6/24/2021 5:51:10 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614052-012

Collection Date: 6/12/2021

Client Sample ID: PS-04-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	2.1	1.0		µg/L	1	6/24/2021 6:02:22 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614052-013

Collection Date: 6/12/2021

Client Sample ID: PS-04-B

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.5	1.0		µg/L	1	6/24/2021 6:13:33 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614052-014

Collection Date: 6/12/2021

Client Sample ID: PS-05-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 6:17:18 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-015

Collection Date: 6/12/2021

Client Sample ID: PS-05-B

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.3	1.0		µg/L	1	6/24/2021 6:21:03 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 25-Jun-21

CLIENT: Hudson Falls Central Schools

LabWork Order: 210614052

Project:

Primary School

PO#: 2022112

Lab SampleID: 210614052-016

Collection Date: 6/12/2021

Client Sample ID: PS-FAC

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 6:24:46 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-017

Collection Date: 6/12/2021

Client Sample ID: PS-08

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.3	1.0		µg/L	1	6/24/2021 6:28:30 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614052-018

Collection Date: 6/12/2021

Client Sample ID: PS-09-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 6:32:13 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-019

Collection Date: 6/12/2021

Client Sample ID: PS-09-B

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 6:35:56 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-020

Collection Date: 6/12/2021

Client Sample ID: PS-10-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.7	1.0		µg/L	1	6/24/2021 6:39:40 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 25-Jun-21

CLIENT: Hudson Falls Central Schools

LabWork Order: 210614052

Project:

Primary School

PO#: 2022112

Lab SampleID: 210614052-021

Collection Date: 6/12/2021

Client Sample ID: PS-10-B

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 6:58:17 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-022

Collection Date: 6/12/2021

Client Sample ID: PS-11-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 7:09:31 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-023

Collection Date: 6/12/2021

Client Sample ID: PS-12-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 7:13:16 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-024

Collection Date: 6/12/2021

Client Sample ID: PS-13-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 7:17:00 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-025

Collection Date: 6/12/2021

Client Sample ID: PS-13-B

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 7:20:43 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 25-Jun-21

CLIENT: Hudson Falls Central Schools

LabWork Order: 210614052

Project:

Primary School

PO#: 2022112

Lab SampleID: 210614052-026

Collection Date: 6/12/2021

Client Sample ID: PS-14-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 7:24:27 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-027

Collection Date: 6/12/2021

Client Sample ID: PS-14-B

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 7:28:11 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-028

Collection Date: 6/12/2021

Client Sample ID: PS-17

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	2.0	1.0		µg/L	1	6/24/2021 7:31:54 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614052-029

Collection Date: 6/12/2021

Client Sample ID: PS-18

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	1.9	1.0		µg/L	1	6/24/2021 7:43:05 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 210614052-030

Collection Date: 6/12/2021

Client Sample ID: PS-GGB-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 7:46:48 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 25-Jun-21

CLIENT: Hudson Falls Central Schools

LabWork Order: 210614052

Project:

Primary School

PO#: 2022112

Lab SampleID: 210614052-031

Collection Date: 6/12/2021

Client Sample ID: PS-GGB-B

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 7:50:32 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-032

Collection Date: 6/12/2021

Client Sample ID: PS-BGB-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 8:01:46 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-033

Collection Date: 6/12/2021

Client Sample ID: PS-BGB-B

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 8:05:31 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-034

Collection Date: 6/12/2021

Client Sample ID: PS-MFB

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 8:09:15 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-035

Collection Date: 6/12/2021

Client Sample ID: PS-GFB

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 8:12:59 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 25-Jun-21

CLIENT: Hudson Falls Central Schools

LabWork Order: 210614052

Project:

Primary School

PO#: 2022112

Lab SampleID: 210614052-036

Collection Date: 6/12/2021

Client Sample ID: PS-19-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 8:16:43 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-037

Collection Date: 6/12/2021

Client Sample ID: PS-20-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 8:27:54 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-038

Collection Date: 6/12/2021

Client Sample ID: PS-NUR-SICK

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 8:31:38 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-039

Collection Date: 6/12/2021

Client Sample ID: PS-21-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 8:35:22 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 210614052-040

Collection Date: 6/12/2021

Client Sample ID: PS-22-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: KH

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/24/2021 8:39:06 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 25-Jun-21

CLIENT: Hudson Falls Central Schools

LabWork Order: 210614052

Project:

Primary School

PO#: 2022112

Lab SampleID: 210614052-041

Collection Date: 6/12/2021

Client Sample ID: PS-23-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 11:20:23 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-042

Collection Date: 6/12/2021

Client Sample ID: PS-24-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 11:31:37 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-043

Collection Date: 6/12/2021

Client Sample ID: PS-25-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 11:42:48 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-044

Collection Date: 6/12/2021

Client Sample ID: PS-26-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 11:46:32 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-045

Collection Date: 6/12/2021

Client Sample ID: PS-27-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 11:50:16 AM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 25-Jun-21

CLIENT: Hudson Falls Central Schools

LabWork Order: 210614052

Project:

Primary School

PO#: 2022112

Lab SampleID: 210614052-046

Collection Date: 6/12/2021

Client Sample ID: PS-28-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 11:54:00 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-047

Collection Date: 6/12/2021

Client Sample ID: PS-29-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 11:57:44 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-048

Collection Date: 6/12/2021

Client Sample ID: PS-30-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 12:01:28 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-049

Collection Date: 6/12/2021

Client Sample ID: PS-31

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 12:05:12 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-050

Collection Date: 6/12/2021

Client Sample ID: PS-32

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 12:08:57 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 25-Jun-21

CLIENT: Hudson Falls Central Schools

LabWork Order: 210614052

Project:

Primary School

PO#: 2022112

Lab SampleID: 210614052-051

Collection Date: 6/12/2021

Client Sample ID: PS-33

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	1.2	1.0		µg/L	1	6/25/2021 12:12:41 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-052

Collection Date: 6/12/2021

Client Sample ID: PS-34-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 12:31:21 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-053

Collection Date: 6/12/2021

Client Sample ID: PS-35-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 12:35:06 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-054

Collection Date: 6/12/2021

Client Sample ID: PS-36-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 12:38:50 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-055

Collection Date: 6/12/2021

Client Sample ID: PS-37-A

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 12:42:35 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 25-Jun-21

CLIENT: Hudson Falls Central Schools

LabWork Order: 210614052

Project:

Primary School

PO#: 2022112

Lab SampleID: 210614052-056

Collection Date: 6/12/2021

Client Sample ID: PS-38

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	2.3	1.0		µg/L	1	6/25/2021 12:46:19 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-057

Collection Date: 6/12/2021

Client Sample ID: PS-41

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 12:50:03 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 210614052-058

Collection Date: 6/12/2021

Client Sample ID: PS-DF-1-BF

Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 6/15/2021)

Lead	ND	1.0		µg/L	1	6/25/2021 12:53:48 PM
------	----	-----	--	------	---	-----------------------



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210614052

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Hudson Falls CSD		Address: 47 Vaughn Rd Hudson Falls NY 12839	
Send Report to: David McKeighan dmckeighan@hfcsl.org		Project Name (Location): Primary School	
Client Phone#: (518) 681-4572		Client PO #: 2022112	
Client Email: dmckeighan@hfcsl.org		Samplers Name: David McKeighan	
		Samplers Signature: <i>David McKeighan</i>	

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
001	PS-KT-1	6/12/21	1:30	A					
002	PS-KT-2			P					
003	PS-KT-3			A					
004	PS-KTB			P					
005	PS-OFF			A					
006	PS-NURSE-1			P					
007	PS-NUR-2			A					
008	PS-01-A			P					
009	PS-02-A			A					
010	PS-03-A			P					
011	PS-03-B			A					
012	PS-04-A			P					
013	PS-04-B			A					
014	PS-05-A			P					
015	PS-05-B			A					
				P					

Shipment Arrived Via: FedEx UPS <u>Client</u> AES Other:		Special Instructions/Remarks: 	
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.			
Relinquished by: (Signature)			

Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Date	Time
Relinquished by: (Signature)		Date	Time

Sample Temperature <u>Ambient</u> ~ Chilled ~ Chilling Begun Notes: 22°C		Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other		Received Within Holding Times: Y / N Notes:	
Custody Seal Intact: Y / N Bottles AES: Y / N					



210614052



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210614052

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Hudson Falls CSD		Address: 47 Vaughn Rd Hudson Falls NY 12839	
Send Report to: David McKeighan dmckeighan@hfcscd.org		Project Name (Location): Primary School	
Client Phone #: 518-681-4572		Client PO #: 2022112	
Client Email: dmckeighan@hfcscd.org		Samplers Name: David McKeighan	
		Samplers Signature: <i>David McKeighan</i>	

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
016	PS-FAC	6/12/21	A						
017	PS-08		P						
018	PS-09-A		A						
019	PS-09-B		P						
020	PS-10-A		A						
021	PS-10-B		P						
022	PS-11-A		A						
023	PS-12-A		P						
024	PS-13-A		A						
025	PS-13-B		P						
026	PS-14-A		A						
027	PS-14-B		P						
028	PS-17		A						
029	PS-18		P						
030	PS-GGB-A		A						

Shipment Arrived Via: FedEx UPS <u>Client</u> AES Other:		Special Instructions/Remarks:	
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard			
NOTE: Samples received after 3:30pm are considered next business day.			

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time
	<i>[Signature]</i>	6/14/21	3:05pm

Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes: 22°C	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: Y / N Notes:
Custody Seal Intact: Y / N		
Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210614052

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Hudson Falls CSD	Address: 47 Vaughn Rd Hudson Falls NY 12839	
Send Report to: David McKeighan dmckeighan@hfcscd.org	Project Name (Location): Primary School	Samplers Name: David McKeighan
Client Phone #: 518-681-4572	Client PO #: 2022112	Samplers Signature: <i>David McKeighan</i>
Client Email: dmckeighan@hfcscd.org		

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
031	PS-GGB-B	6/12/21	2:30	P					
032	PS-BGB-A			P					
033	PS-BGB-B			P					
034	PS-MFB			P					
035	PS-GFB			P					
036	PS-19-A			P					
037	PS-20-A			P					
038	PS-NUR-SICK			P					
039	PS-21-A			P					
040	PS-22-A			P					
041	PS-23-A			P					
042	PS-24-A			P					
043	PS-25-A			P					
044	PS-26-A			P					
045	PS-27-A			P					

Shipment Arrived Via:

FedEx UPS Client AES Other: _____

Special Instructions/Remarks:

Turnaround Time Requested:

1 Day 2 Day 3 Day 5 Day Standard

NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time
	<i>[Signature]</i>	6/14/21	3:05pm

Sample Temperature Ambient ~ Chilled ~ Chilling Begun Notes: 22°C	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
Custody Seal Intact: Y / N Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

210614052

COC Reference:

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Hudson Falls CSD	Address: 47 Vaughn Rd Hudson Falls NY 12839
Send Report to: David McKeighan dmckeighan@hfcscd.org	Project Name (Location): Primary School
Client Phone #: 518-681-4572	Client PO #: 2022112
Client Email: dmckeighan@hfcscd.org	Samplers Name: David McKeighan
	Samplers Signature: <i>David McKeighan</i>

AES Sample Number	Client Sample Identification & Location	Date Sampled	Time A=am P=pm	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
046	PS-28-A	6/12/21	A						
047	PS-29-A		P						
048	PS-30-A		A						
049	PS-31		P						
050	PS-32		A						
051	PS-33		P						
052	PS-34-A		A						
053	PS-35-A		P						
054	PS-36-A		A						
055	PS-37-A		P						
056	PS-38		A						
057	PS-41		P						
058	PS-DF-1-BE		A						
			P						
			A						
			P						

Shipment Arrived Via:

FedEx UPS Client AES Other:

Special Instructions/Remarks:

Turnaround Time Requested:

1 Day 2 Day 3 Day 5 Day Standard

NOTE: Samples received after 3:30pm are considered next business day.

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time
	<i>[Signature]</i>	6/14/21	3:05pm

Sample Temperature <u>Ambient</u> ~ Chilled ~ Chilling Begun Notes: 22°C	Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other	Received Within Holding Times: <u>Y</u> / N Notes:
Custody Seal Intact: Y / N		
Bottles AES: <u>Y</u> / N		



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.