



Mr. Joseph M. Manney | Buildings & Grounds
Director of Facilities II Office: (518) 681-4571

January 31, 2025

Dear Parents and Staff:

This is a follow up letter regarding the drinking water sampling taken at the Primary School. The outlet that tested above the acceptable level of 5 ppb has been remediated and retested, still above acceptable standard of less than 5 ppb. Remediation is ongoing, and we are working diligently to correct this issue.

Location:	Test Results
Room 3 Classroom sink	5.1ppb, Remediation still in progress

Sincerely,

Joseph M. Manney

Director of Facilities II